Twin Spot

Code: TS/4/ST/WH/865

SELF TEST - Emergency LED Twin Spot, 2x250lm, IP65

CQR Emergency Twin Spots are ideal for larger areas whether requiring our medium or high output versions, with narrow or wide beam angles and self-test options available.

Features & Benefits

- Emergency Twin Spots: 500lm & 1000lm versions
- 1000lm output version suitable for larger areas
- Narrow or wide beam angle options
- Self-test function available
- Available in white and black
-

Technical Data

IP Rating	65

Electrical

Battery	LiFePO4 6.4V 3300mAh
Voltage / Frequency	AC 220-240V 50/60Hz
Running Current (A)	0.03
Charging Power (W)	2.2
Emergency Power (W)	4
Power Factor	0.32
Inrush Current (A / us)	4A / 100us
Electrical Class	2

Features

Mounting Method	Wall

Photometric Data

Emergency Mode Lumens	500
CCT (K)	6500
Beam Angle	120°
Lumen Maintenance L70 (Hrs)	50000
CRI	80

Emergency

Emergency Duration (Hrs)	3
Maintained / Non-Maintained	Non-Maintained
Self-Test	Yes

Mechanical

Mounting Method	Wall
Housing Material	Polycarbonate
Dimensions (LxWxH mm)	300x287.5x68.5

Warranty

Product Warranty	5

CQR Security, 125 Pasture Road, Moreton, Wirral, CH46 4TH

Sales: +44(0)151 6061000 (9am to 5pm Monday to Friday) **Tech:** +44(0)151 606 6311

sales@cqr.co.uk | www.cqr.co.uk

Company Registration Number: 5192024 | VAT Number: 309 0409 27

This document is uncontrolled if printed, all information is subject to change. Generated on 9/23/2025 10:51:57 AM

90mm

66mm

190mm

300mm

35mm

287.5mm

68.5mm

288mm x 300mm

90

0

180

270

C Halfplanes

180.0 — 0.0

270.0 — 90.0

Flux 251 lm
Maximum 372.19 cd/klm
Position C=105.00 G=5.00
Efficiency: 100.12%
Date: 02-04-2022
Asymmetrical

120° Gamma Angles 180° 120°

105° 105°

80

90° 90°

80

75° 75°

160

60° 60°

240

45° 45°

320

cd/klm

400

30° 15° 0° 15° 30°

CQR Security, 125 Pasture Road, Moreton, Wirral, CH46 4TH

Sales: +44(0)151 6061000 (9am to 5pm Monday to Friday) **Tech:** +44(0)151 606 6311

sales@cqr.co.uk | www.cqr.co.uk

Company Registration Number: 5192024 | VAT Number: 309 0409 27

This document is uncontrolled if printed, all information is subject to change. Generated on 9/23/2025 10:51:57 AM